

Certification of restoration plasters / restoration plaster  
systems according to WTA – Data Sheet 2-9-04/D

**Form 1 for Inspection Bodies**  
**Rough Cast WTA**

Manufacturer's product designation:  
(Note: The product designation must correspond to the technical data sheet.)

Annex \_\_\_\_\_ to Test Report No. \_\_\_\_\_ of \_\_\_\_\_

Initial test  Repeat test within the scope of external monitoring

Property	Unit	Test Method	WTA Requirement 2-9-04/D	Test Result Values		
				lowest	highest	average
Solid mortar						
Water penetration after 1 hour (tested on discs)	mm	Chap.6.3.7 <sup>1)</sup>	> 5			
Water penetration after 24 hours (tested on discs)	mm	Chap.6.3.7 <sup>1)</sup>	20 (corresponds to thickness of test specimen)			

<sup>1)</sup> as per WTA Data Sheet 2-9-04/D

**Explanatory notes**

The inspection of a spray cast belonging to the system is only necessary if the degree of coverage of the spray cast is higher than 50 % or if the manufacturer demands a closed spray in his technical documentation or does not expressly exclude it.

A spray cast for which the manufacturer only requires a net-shaped application in his technical documentation does not have to be tested according to WTA.

*To be completed by the Certification Committee*

*Inspected on:*

*Inspected by:*

Requirements fulfilled

not fulfilled

*Comments:*